

1. Unique identification code of the product-type: **Twin- wall chimney system Vulcano Plus (316/304)**
2. Type, batch or serial number or any other element allowing identification of the construction product: **24.806142**
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer: **for the discharging combustion products from heating plants.**
4. Name, registered trade name or registered trade mark and contact address of the manufacturer:
**„Dumvadu meistars”, Ltd, no. 50003731161,9 Rubenkalna str., Riga, LV -1057, Republic of Latvia,
Tālr. +371 67138590, fakss +371 67138596.E-mail: dm@dumvadumeistars.lv ; www.dumvadumeistars.lv**
5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks:
**Dumvadumeistars”, Ltd, no. 50003731161,9 Rubenkalna str., Riga, LV -1057, Republic of Latvia,
Tālr. +371 67138590, fakss +371 67138596.E-mail: dm@dumvadumeistars.lv ; www.dumvadumeistars.lv**
6. System or systems of assessment and verification of constancy of performance of the construction product: **2+**
7. In case of the declaration of performance concerning a construction product covered by a harmonised standard: **LVS EN 1856-1:2009**, (name and identification number of the notified body, if relevant) **Certification Centre of the Latvian Academy of Sciences, NB 1327** performed under system **2+** (description of third party tasks as set out in Annex V) **and issued certificate of conformity of the factory production control No 1327-CPR-0881.**

(certificate of constancy of performance, certificate of conformity of the factory production control, test/calculation reports – as relevant)

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: **not provided**, (name and identification number of the Technical Assessment Body, if relevant) issued (reference number of the European Technical Assessment) on the basis of, (reference number of the European Assessment Document) performed under system (description of the third party tasks) and issued (certificate of constancy of performance, certificate of conformity of the factory production control, test/calculation reports – as relevant)
9. Declared performance

Designation T600-N1-W-Vm-L50050-G150

The essential characteristics	The declared performance	The corresponding harmonised standard
Tightness	N1	EN 1856-1:2009
Fireresistance, distance to flammable stuff	150mm	EN 1856-1:2009
Thermal resistance	T 600	EN 1856-1:2009
Steam and water penetration	W	EN 1856-1:2009
Corrosion resistance	Vm, Pass	EN 1856-1:2009
Thermal Shock	Pass	EN 1856-1:2009
Compression strenght	2,2 kN	EN 1856-1:2009
Compressive strenght of wall console type1	Pass	EN1859:2013
Compressive strenght of wall console type2	Pass	EN1859:2013
Compressive strenght of roof console	Pass	EN1859:2013
Lateral strenght	Pass	EN1859:2013
Wind load	Pass	EN1859:2013

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Jevgenijs Ignatovičs
(name and function)

Riga, January
(place and date of issue) (signature)